



THE CORPORATION OF THE TOWNSHIP OF NORWICH
PUBLIC WORKS DEPARTMENT

Hydro Road Crossing Permit

Applicant must follow ALL criteria outlined on this form.

- The applicant is responsible for all utility locates and restoration to any damage to utility plant located in the road right-of-way.
- Only gravel roads will be “open cut”, any hard surface road will require directional bore.
- The hydro lines must be in heavy-duty conduit (db2 or equivalent) and cross the road at 90 degrees. Conduit must be a minimum of 1.5 metres below ditch bottom across the entire road allowance, (Property line to property line), and marked as high voltage on both sides of the road.
- The road right-of-way must be restored to pre-construction condition following any work performed in the right-of-way.
- Any road closure must be between 9:00 am and 3:00 pm during the school season. Should there be a road closure, for any period of time, the contractor is responsible for notification of all emergency services.
- The contractor must abide by the latest edition of all applicable laws, acts and regulations including but not limited to the Occupational Health and Safety Act and the Ontario Traffic Manual Book 7.

Address of crossing _____

Applicant's name and phone # _____

Contractor name and phone# _____

Approved by _____

Permit Fee is \$25.00

Damage deposit cheque for \$500.00 will be returned after satisfactory completion.

Marty Lenaers C.R.S.I.