

RESIDENTIAL MECHANICAL VENTILATION DESIGN SUMMARY
for design and performance of residential ventilation systems to OBC 2012 Div. B 9.32

| | | | |
|---|---|---|--------------------------------------|
| LOCATION | 1. Location Township: _____ Civic Address: _____ | 8. TVC System <input type="checkbox"/> HRV <input type="checkbox"/> Central Exhaust <input type="checkbox"/> Multiple Fans | TVC SYSTEM |
| BUILDER | 2. Builder Name: _____ Address: _____ City: _____ Postal Code: _____ Ph: _____ Fax: _____ | 9. Principal Exhaust Fan Capacity (PEF) Master Bedroom _____ @ 30 CFM(15L/S) _____ Other Bedrooms _____ @ 15 CFM(7.5L/S) _____ Total _____ | PRINCIPAL EXH. FAN CAPACITY |
| DESIGNER | 3. Designer Name: _____ Address: _____ Postal Code: _____ City: _____ Ph: _____ Fax: _____ Firm BCIN: _____ Designer BCIN: _____ HRAI#: _____ | | PRINCIPAL EXHAUST FAN |
| HEATING SYSTEM | 4. Heating Systems <input type="checkbox"/> Forced Air <input type="checkbox"/> Non Forced Air <input type="checkbox"/> Oil <input type="checkbox"/> Electric <input type="checkbox"/> Gas <input type="checkbox"/> Other | 10. Principal Exhaust Fan Location _____ Manufacturer _____ Model _____ <input type="checkbox"/> HVI rated Design Airflow High _____ Low _____ Sones _____ If Using HRV/ERV: _____ % Sensible Efficiency @ 0°C _____ watts _____ % Sensible Efficiency @ -25°C _____ watts | PRINCIPAL EXHAUST FAN |
| HEATING SYSTEM COMBUSTION APPLIANCES | 5. Combustion Appliances 9.32.3.1.(1) a) Direct Vent b) Induced Draft c) Natural Draft d) Solid Fuel Appliances e) No combustion appliances | 11. Supplemental Exhaust Fan Capacity (SEF) Total Ventilation Capacity _____ Less Principle Ventilation Capacity _____ Required Supplemental Ventilation Capacity _____ | SUPPLEMENTAL EXHAUST CAPACITY |
| HOUSE TYPE | 6. Type of House 9.32.3.1.(2) <input type="checkbox"/> Type 1 a) or b) type appliances only <input type="checkbox"/> Type 2 a) or b) type appliances with a d) type appliance <input type="checkbox"/> Type 3 any type c) appliance = part 6 design <input type="checkbox"/> Type 4 electric space heat | | ADDITIONAL EXHAUST EQUIPMENT |
| SYSTEM DESIGN OPTION | 7. System Design Option Exhaust only forced air system/coupled HRV with extended exhaust or simplified coupled HRV full ducting/not coupled to forced air Part 6 design | 12. Additional Equipment Fan 2 Location _____ Sones _____ Manufacturer/Model _____ <input type="checkbox"/> TVC Design airflow _____ CFM Fan 3 Location _____ Sones _____ Manufacturer/Model _____ <input type="checkbox"/> TVC Design airflow _____ Fan 4 Location _____ Sones _____ Manufacturer/Model _____ <input type="checkbox"/> TVC Design airflow _____ | ADDITIONAL EXHAUST EQUIPMENT |
| TOTAL VENTILATION CAPACITY (TVC) | 8. TVC Capacity OBC 9.32.3.3 Bsmt & Master bedroom _____ @ 20 CFM (10 L/S) _____ Other Bedrooms _____ @ 10 CFM (5 L/S) _____ Bathrooms & Kitchen _____ @ 10 CFM (5 L/S) _____ Other Habitable Rooms _____ @ 10 CFM (5 L/S) _____ Total Ventilation Capacity (TVC) _____ | 13 Designer Consent I, _____ have reviewed and take responsibility for the design work described in this document and I am qualified in the appropriate categories. Date: / / Signature: _____ | DESIGNER CONSENT |

Conversion Note: 1 L/S = 2 CFM (For a hard conversion, use 1 L/S = 20118 CFM)